

Himachal Pradesh
Public Works Department

No.PW-BSR/WA-building/2020-

To

20361-62


Dated:- 11-03-2022

The Headmaster,
T.R.D.A.V Public Sr. School Kangoo ,
Tehsil Nadaun Distt Hamirpur,(H.P).

Subject: - Regarding Building safety certificate thereof.

The building Safety Certificate, duly Countersigned is sent herewith for taking further necessary
action.

DA-As above



Executive Engineer
Barsar Division,
HP.PWD, Barsar

Copy to the Assistant Engineer, Dhaneta Sub Division, HPPWD, Dhaneta w.r.to above for
information.

Executive Engineer
Barsar Division,
HP.PWD, Barsar.

Building Certificate

The building of the ~~TR. D.A.V. Pub. Sr. Sec. School~~ ^{Idangn} Tehsil & Distt Hamirpur (H.P) is inspected along with concerned Junior Engineer. The building has neither been designed nor constructed by this department. No earthquake resistant norms have been adopted for this building. No structure drawing approved by the competent Government Agency have been produced. The structure is a Non Engineering structure. Hence the structure safety of this building cannot be ensured specially from earthquake point of view. The year of construction of this building is 2003 as intimated by the concerned school owner (copy enclosed). This department will not be responsible for any type of loss of life and property etc. If this structure falls under any circumstances. However as per visual appearance, the building seems safe for functioning for the year 2022-24.

~~Junior Engineer,
Section - Kangra~~

C/S
[Signature]
Executive Engineer
Barsar Division
H.P.W.D. Barsar

[Signature]
Assistant Engineer
Dhaneta Sub -Division
HP.PWD Dhaneta

Dhaneta